

APPENDIX

G

COMBUSTIBLE GAS DATA



**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
5-Jan-07	% LEL	0	0	0	0				too much mud	0	0	0	0	0	0	0	
11-Jan-07	% LEL	0	0	0	0				3.8	0	0	0	0	0	0	0	
19-Jan-07	% LEL	0	0	0	0				0.8	0	0	0	0	0	0.1	0	
26-Jan-07	% LEL	0	0	0	0				0.6	0	0	0	0	0	0	0	
12-Feb-07	% LEL	0	0	0	0				37*	0	0	0.2	0	0	0	0	
21-Feb-07	% LEL	0	0	0	0				24*	0	0.1	0.1	0	0	0	0	
7-Mar-07	% LEL	0	0	0	0				47*	37*	0	0	0	0	0	0	
16-Mar-07	% LEL	0	0	0	0				21*	25*	0	0	0	0	0	0	
23-Mar-07	% LEL	0	0	0	0				too much mud	55*	0	0	0	0	0	0	
29-Mar-07	% LEL	0	0	0	0				23*	0	0	0	0	0	0	0	
13-Apr-07	% LEL	0	0	0	0				15*	0	0	0	0	0	0	0	
30-Apr-07	% LEL	0	0	0	0				25*	0	0	0	0	0	0	0	
17-May-07	% LEL	0	0	0	0				46*	0	0	0	0	0	0	0	
25-May-07	% LEL	0	0	0	0				49*	1.4	0	0.1	0	0	0	0	
31-May-07	% LEL	0	0	0	0				27*	2.9	0	0.3	0	0	0	0	
8-Jun-07	% LEL	0	0	0	0				24*	7.7	0	0.5	0	0	0	0	
15-Jun-07	% LEL	0	0	0	0				22*	0.2	0.3	0.5	0	0	0	0	
13-Jul-07	% LEL	0	0	0	0				0.8	16	0	0.2	0	0	0	0	
26-Jul-07	% LEL	0	0	0	0				0.7	8.2	0.4	0.4	0	0	0	0	
10-Aug-07	% LEL	0	0	0	0				0.5	16*	0	0.2	0	0	0	0	
17-Aug-07	% LEL	0	0	0	0				Forgot to read	10*	0.2	0.2	0	0	0	0	
24-Aug-07	% LEL	0	0	0	0				31	8*	0	0.2	0	0	0	0	
4-Sep-07	% LEL	0	0	0	0				63*	6*	0.4	0.4	0	0	0	0	
14-Sep-07	% LEL	0	0	0	0					1.2	0	0.2	0	0	0	0	
21-Sep-07	% LEL	0	0	0	0					0.5	0	0.2	0	0	0	0	
5-Oct-07	% LEL	0	0	0	0					0.4	0	0	0	0	0	0	
2-Nov-07	% LEL	0	0	0	0					0.7	0	0.2	0	0	0	0	
16-Nov-07	% LEL	0	0	0	0					33	0	0.2	0	0	0	0	
6-Dec-07	% LEL	0	0	0	0					0	0	0.1	0	0	0	0	
21-Dec-07	% LEL	0	0	0	0					0	0	0	0	0	0	0	

Notes: · Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)
· Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007

· * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)
· Blank denotes data not available

**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
16-Jan-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
8-Feb-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
22-Feb-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
28-Feb-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
10-Mar-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
8-Apr-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
18-Apr-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
1-May-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
12-May-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
5-Jun-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
19-Jun-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
26-Jun-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
10-Jul-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
25-Jul-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
31-Jul-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
14-Aug-08	% LEL	0	0	0	0				0	0	0	0	0.5	0	0		
21-Aug-08	% LEL	0	0	0	0				0	0	0	0	0.5	0	0		
28-Aug-08	% LEL	0	0	0	0				0	0.4	0.7	0	0	0	0		
3-Sep-08	% LEL	0	0	0	0				0	0.5	0.5	0	0	0	0		
11-Sep-08	% LEL	0	0	0	0				0	0	0.2	0	0	0	0		
10-Oct-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
17-Oct-08	% LEL	0	0	0	0				0	0	0.5	0	0	0	0		
31-Oct-08	% LEL	0	0	0	0				0	0	0.5	0	0	0	0		
6-Nov-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
21-Nov-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		
12-Dec-08	% LEL	0	0	0	0				0	0	0	0	0	0	0		

Notes: · Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)
· Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007

· * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)
· Blank denotes data not available

**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
9-Jan-09	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
23-Jan-09	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
6-Feb-09	% LEL	0	0	0	0	0			0.6	0	0	0	0	0	0		
13-Feb-09	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
25-Feb-09	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
13-Mar-09	% LEL	0	0	Locked	0	0			0	0	0	0	0	0	0		
27-Mar-09	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
24-Apr-09	% LEL	0	0	0	0	0			0	0	0.1	0	0	0	0		
30-Apr-09	% LEL	0	0	0	0	0			0	0	0.1	0	0	0	0		
28-May-09	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
5-Jun-09	% LEL	0	0	0	0.1	0			0	0	0	0	0	0	0		
25-Jun-09	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
10-Jul-09	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
17-Jul-09	% LEL	0	0	0	0	0			0.1	0	1.2	0	0	0	0		
30-Jul-09	% LEL	0	0	0	0	0			0	0	0.3	0	0	0	0		
14-Aug-09	% LEL	0	0	0	0	0			0	0	0.1	0	0	0	0		
28-Aug-09	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
20-Oct-09	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
9-Nov-09	% LEL	0	0	0	0	0			0	0	0.4	0	0	0	0		
18-Nov-09	% LEL	0	0	0	0	0			0	0.1	0.4	0	0	0	0		
26-Nov-09	% LEL	0	0	0	0	0			0	0	0.4	0	0	0	0		
3-Dec-09	% LEL	0	0	0	0	0			0	0	0.2	0	0	0	0		
16-Dec-09	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		

Notes: · Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)
· Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007

· * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)
· Blank denotes data not available

**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
8-Jan-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
15-Jan-10	% LEL	0	0	0	0	0			0.2	0.2	0.5	0	0	0	0		
29-Jan-10	% LEL	0	0	0	0	0			0.5	0	0	0	0	0	0		
5-Feb-10	% LEL	0	0	0	0	0			0.1	0	0	0	0	0	0		
11-Feb-10	% LEL	0	0	0	0	0			0.4	0	0.3	0	0	0.1	0		
19-Feb-10	% LEL	0	0	0	0	0			0.2	0	0.1	0	0	0	0		
5-Mar-10	% LEL	0	0	0	0	0			0.2	0	0.2	0	0	0	0		
19-Mar-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
24-Mar-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
22-Apr-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
3-May-10	% LEL	0	0	0	0	0			0.3	0	0.3	0	0	0	0		
10-May-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
19-May-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
25-May-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
11-Jun-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
25-Jun-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
15-Jul-10	% LEL	0	0.3	0	0	0			0	0	0.3	0	0	0	0		
28-Jul-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
20-Aug-10	% LEL	0	0	0	0	0			0	0.3	0.8	0	0	0	0		
7-Oct-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
15-Oct-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
19-Oct-11	% LEL	0	0	0	0	0			0.1	0	0	0	0	0	0		
1-Nov-10	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
19-Nov-10	%LEL	0	0	0	0	0			0	0	0.3	0	0	0	0		

Notes: · Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)
· Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007

· * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)
· Blank denotes data not available

**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
7-Jan-11	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
13-Jan-11	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
10-Feb-11	% LEL	0	0	0	0	0			0	0	0.5	0	0	0	0		
23-Feb-11	% LEL	0	0	0	0	0			0.2	0	0	0	0	0	0		
8-Mar-11	% LEL	0	0	0	0	0			0	0	0	0	0.3	0	0		
1-Apr-11	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
7-Apr-11	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
29-Apr-11	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
6-May-11	% LEL	0.1	0	0	0	0			0	0	0	0	0	0	0		
27-May-11	% LEL	0.1	0	0	0	0			0	0	0	0	0	0	0		
7-Jun-11	% LEL	0	0	0.2	0.3	0			0	0.2	0.2	0.2	0.1	0.1	0.1	0	
8-Jul-11	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
14-Jul-11	% LEL	0	0	0	0	0			0	0.3	0.4	0	0	0	0		
26-Jul-11	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
11-Aug-11	% LEL	0	0	0	0	0			0	0	0.2	0	0	0	0		
23-Aug-11	% LEL	0	0	0	0	0			0.2	0	0.6	0	0	0	0		
1-Sep-11	% LEL	0.1	0	0	0	0			0.1	0.1	0.2	0	0	0	0		
9-Sep-11	% LEL	0.1	0	0	0	0			0	0	0.6	0	0	0	0		
16-Sep-11	% LEL	0	0	0	0	0			0	0	0.6	0	0.2	0	0		
7-Oct-11	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
25-Oct-11	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
18-Nov-11	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
25-Nov-11	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
7-Dec-11	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		

Notes: · Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)
· Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007

· * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)
· Blank denotes data not available

**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
5-Jan-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
13-Jan-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
13-Feb-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
6-Mar-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
13-Mar-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
21-Mar-12	% LEL	0	0	0	0	0			0	0	0.5	0	0	0	0		
29-Mar-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
12-Apr-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
19-Apr-12	% LEL	0	0	0	0	0			0.1	0	1	0	0	0	0		
11-May-12	% LEL	0	0	0	0	0			0	0	0.7	0	0	0	0		
15-May-12	% LEL	0	0	0	0	0			0	0	0.6	0	0	0	0		
25-May-12	% LEL	0	0	0	0	0			0.5	0.3	0.2	0	0	0	0		
6-Jun-12	% LEL	0	0	0	0	0			0	0	0.2	0	0	0	0		
22-Jun-12	% LEL	0	0	0	0	0			0.8	0	1.9	0	0	0	0		
29-Jun-12	% LEL	0	0	0	0	0			1	0	1.1	0	0	0	0		
13-Jul-12	% LEL	0	0	0	0	0			0.9	0.7	1.1	0	0	0	0		
21-Jul-12	% LEL	0	0	0	0	0			0.9	0.7	1	0	0	0	0		
2-Aug-12	% LEL	0	0	0	0	0			1	0	0.9	0	0	0	0		
17-Aug-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
24-Aug-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
21-Sep-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
1-Oct-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
8-Nov-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
14-Nov-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
22-Nov-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
7-Dec-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
13-Dec-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
21-Dec-12	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		

Notes: · Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)
· Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007

· * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)
· Blank denotes data not available

**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
18-Jan-13	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
25-Jan-13	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
5-Feb-13	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
13-Feb-13	% LEL	0	0	0	0	0			0	0	0	0	0	0.2	0		
28-Feb-13	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
7-Mar-13	% LEL	0	0	0	0	0			0	0	0.1	0	0	0	0		
15-Mar-13	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
22-Mar-13	% LEL	0	0	0	0	0			0	0	0.2	0	0	0.1	0		
28-Mar-13	% LEL	0	0	0	0	0.4			0	0.3	0.2	0	0	0	0		
3-May-13	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
9-May-13	% LEL	0	0	0	0	0			0	0	0	0	0	0	0.3		
31-May-13	% LEL	0	0.1	0	0	0			0	0.2	0.8	0	0	0	0.2		
14-Jun-13	% LEL	0	0.3	0	0	0			0	0	0	0	0	0	0		
5-Jul-13	% LEL	0	0.1	0	0	0			0.3	0	0.2	0	0	0	0		
19-Jul-13	% LEL	0.2	0	0	0	0			0.2	1.0	0.2	0	0	0	0		
2-Aug-13	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
16-Aug-13	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
20-Sep-13	% LEL	0	0	0	0	0			0	0	0.9	0	0	0	0		
3-Oct-13	% LEL	0	0	0	0	0			0	0.5	0	0	0	0	0		
1-Nov-13	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
2-Dec-13	% LEL	0	0	0	0	0			0	0	0.1	0	0	0	0		
30-Dec-13	% LEL	0	0	0	0	0			0	0	0.1	0	0	0	0		

Notes: · Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)
· Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007

· * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)
· Blank denotes data not available

**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
17-Jan-14	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
14-Feb-14	% LEL	0	0	0	0	0			10.4	0	1.0	0	0	0	0		
28-Feb-14	% LEL	0	0	0	0	0				0.2	0	0	0	0	0		
21-Mar-14	% LEL	0	0	0	0	0			8.3	0	0	0	0	0	0		
30-May-14	% LEL	0	0	0	0	0			0.3	0	0	0	0	0	0		
6-Jun-14	% LEL	0	0	0	0	0			0.5	0	0	0	0	0	0		
20-Jun-14	% LEL	0	0	0	0	0			0.1	0	0	0	0	0	0		
4-Jul-14	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
11-Jul-14	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
25-Jul-14	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
1-Aug-14	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
15-Aug-14	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
22-Aug-14	% LEL	0	0	0	0	0			0.3	0	0.1	0	0	0	0		
12-Sep-14	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
26-Sep-14	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
11-Nov-14	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
5-Dec-14	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
12-Dec-14	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
19-Dec-14	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		

Notes: · Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)
· Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007

· * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)
· Blank denotes data not available

**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
2-Jan-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
9-Jan-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
16-Jan-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
23-Jan-15	% LEL	0	0	0	0	0			8.1	0	0	0	0	0	0		
6-Feb-15	% LEL	0	0	0	0	0			4.1	0.1	0	0	0	0	0		
13-Feb-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
20-Feb-15	% LEL	0	0	0	0	0			0	0	0.1	0	0	0	0		
27-Feb-15	% LEL	0	0	0	0	0			0	0.1	0	0	0	0	0		
13-Mar-15	% LEL	0	0	0	0	0			6.9	0	0	0	0	0	0		
20-Mar-15	% LEL	0	0	0	0	0			47	0	0	0	0	0	0		
10-Apr-15	% LEL	1	0.4	0	0	0			100	0	0.7	0	0	0	0		
1-May-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
8-May-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
5-Jun-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
12-Jun-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
23-Jun-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
3-Jul-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
22-Jul-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
7-Aug-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
21-Aug-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
4-Sep-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
30-Sep-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
26-Oct-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
16-Nov-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
27-Nov-15	% LEL	0	0	0	0	0			0	0	0	0	0	0	0		
15-Dec-15	% LEL	0	0	0	0	0			0	0.1	0	0	0	0	0		
29-Dec-15	% LEL	0	0	0	0	0			0	0	0.3	0.2	0	0	0		

Notes: · Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)
· Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007

· * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)
· Blank denotes data not available

**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
26-Jan-16	% LEL	0	0	0	0	0				0	0	0.1	0	0	0	0	
4-Feb-16	% LEL	0	0	0	0	0				0	0	0	0	0	0	0	
10-Feb-16	% LEL	0	0	0	0	0				0	0	0	0	0	0	0	
17-Feb-16	% LEL	0	0	0	0	0				0	0	0	0	0	0	0	
24-Feb-16	% LEL	0	0	0	0	0				0	0	0	0	0	0.2	0	
2-Mar-16	% LEL	0	0	0	0	0				0	0	0	0	0	0	0	
10-Mar-16	% LEL	0	0	0	0	0				0	0	0	0	0	0	0	
23-Mar-16	% LEL	0	0	0	0	0				0	0	0	0	0	0	0	
20-Apr-16	% LEL	0	0	0	0	0				0	0	0	0	0	0	0	
13-May-16	% LEL	0	0	0	0	0	0	0		0	0	0	0	0	0	0	
19-May-16	% LEL	0.3	0	0.2	0.3	0.3	0.3	0.3		0.2	0.2	0	0	0.1	0	0.3	
16-Jul-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
25-Jul-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
2-Aug-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
8-Aug-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
15-Aug-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
25-Aug-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
30-Aug-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
7-Sep-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
20-Sep-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
28-Sep-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
4-Oct-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
11-Oct-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
17-Oct-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
24-Oct-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
31-Oct-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
8-Nov-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
15-Nov-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
21-Nov-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
28-Nov-16	% LEL		0	0	0	0	0	0		0	0	0	0	0	0	0	
13-Dec-16	% LEL		0	0	0	0	0.2	0		Frozen	Frozen	0	0	0	0	0	

Notes: · Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)
 · * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)
 · Blank denotes data not available

· Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007
 · Storage trailer removed from site in the summer of 2016 and lunchroom moved to the Green Barn shop in September 2016.
 · HHW Building and Transfer Station Building added to the program in May 2016.

**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
9-Jan-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0	0		
18-Jan-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0	0		
26-Jan-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0	0		
9-Feb-17	% LEL		0	0	0	0	0	0	Frozen	Frozen	Frozen	0	0	0			
17-Feb-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
23-Feb-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
3-Mar-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
14-Mar-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
22-Mar-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
30-Mar-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
5-Apr-17	% LEL		0	0	0	0	0	0	0	0	0	0	0				
3-May-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
10-May-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
17-May-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
24-May-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
31-May-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
7-Jun-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
15-Jun-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
21-Jun-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
6-Jul-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
14-Jul-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
27-Jul-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
3-Aug-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
10-Aug-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
15-Aug-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
29-Aug-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
6-Sep-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
14-Sep-17	% LEL		0	5	5	5	0	0	0.1	0.1	0	0	0	0			
21-Sep-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
28-Sep-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
5-Oct-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
13-Oct-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
20-Oct-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
27-Oct-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
3-Nov-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
9-Nov-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
17-Nov-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
24-Nov-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
1-Dec-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
8-Dec-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			
15-Dec-17	% LEL		0	0	0	0	0	0	0	0	0	0	0	0			

Notes: · Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)

· * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)

· Blank denotes data not available

· Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007

· Storage trailer removed from site in the summer of 2016 and lunchroom moved to the Green Barn shop in September 2016.

· GW2 was decommissioned in mid-May 2017.

**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
3-Jan-18	% LEL		0	0	0	0	0	0			0	0	0				
12-Jan-18	% LEL		0	0	0	0	0	0			0.2	0	0	0	0		
19-Jan-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
26-Jan-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
15-Feb-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
2-Mar-18	% LEL		0	0	0	0	0	0			frozen	0	0	0	0		
9-Mar-18	% LEL		0	0	0	0	0	0			frozen	0	0	0	0		
23-Mar-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
6-Apr-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
9-Apr-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
12-Apr-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
16-Apr-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
19-Apr-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
23-Apr-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
27-Apr-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
30-Apr-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
11-May-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
25-May-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
8-Jun-18	% LEL		0	0	0	0	0	0			0	0	0	0	0		
28-Jun-18	% LEL		0	0	0	0	0	0			0	0	0	0	0	0	
13-Jul-18	% LEL		0	0	0	0	0	0			0	0	0	0	0	0	
27-Jul-18	% LEL		0	0	0	0	0	0			0	0	0	0	0	0	
10-Aug-18	% LEL		0	0	0	0	0	0			0	0	0	0	0	0	
23-Aug-18	% LEL		0	0	0	0	0	0			0	0	0	0	0	0	
7-Sep-18	% LEL		0	0	0	0	0	0			0	0	0	0	0	0	
20-Sep-18	% LEL		0	0	0	0	0	0			0	0	0	0	0	0	
17-Oct-18	% LEL		0	0	0	0	0	0			0	0	0	0	0	0	
2-Nov-18	% LEL		0	0	0	0	0	0			0	0	0	0	0	0	
15-Nov-18	% LEL		0	0	0	0	0	0			0	0	0	0	0	0	
28-Nov-18	% LEL		0	0	0	0	0	0			frozen	frozen	0	0	0	0	
11-Dec-18	% LEL		0	0	0	0	0	0			0	0	0	0	0	0	
20-Dec-18	% LEL		0	0	0	0	0	0			0	0	0	0	0	0	

Notes: · Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)
 · * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)
 · Blank denotes data not available
 · Moved into new office building in late June 2018; began monitoring.

· Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007
 · Storage trailer removed from site in the summer of 2016 and lunchroom moved to the Green Barn shop in September 2016.
 · GW2 was decommissioned in mid-May 2017.
 · Former office (house) was demolished in August 2018; discontinued monitoring

**Table G-1: Combustible Gas Monitoring Results
Oxford County Waste Management Facility**

Date	Gas Reading	Storage Trailer	Coverall Building	Green Barn		Scalehouse	HHW Building	Transfer Station Building	Gas Monitoring Wells				House				New Landfill Office Building
				Shop	Storage				GW1	GW2	GW3	GW5	Main Floor	Basement	Upstairs	Lunchroom	
10-Jan-19	% LEL		0	0	0	0	0	0			0	0					0
24-Jan-19	% LEL		0	0	0	0	0	0			0	0					0
5-Feb-19	% LEL		0	0	0	0	0	0			0	0					0
22-Feb-19	% LEL		0	0	0	0	0	0			0	0					0
28-Feb-19	% LEL		0	0	0	0	0	0			Frozen	0					0
14-Mar-19	% LEL		0	0	0	0	0	0			0	0					0
29-Mar-19	% LEL		0	0	0	0	0	0			0	0					0
11-Apr-19	% LEL		0	0	0	0	0	0			0	0					0
24-Apr-19	% LEL		0	0	0	0	0	0			0	0					0
9-May-19	% LEL		0	0	0	0	0	0			0	0					0
23-May-19	% LEL		0	0	0	0	0	0			0	0					0
5-Jun-19	% LEL		0	0	0	0	0	0			0	0					0
21-Jun-19	% LEL		0	0	0	0	0	0			0	0					0
4-Jul-19	% LEL		0	0	0	0	0	0			0	0					0
4-Jul-19	% LEL		0	0	0	0	0	0			0	0					0
1-Aug-19	% LEL		0	0	0	0	0	0			0	0					0
15-Aug-19	% LEL		0	0	0	0	0	0			0	0					0
29-Aug-19	% LEL		0	0	0	0	0	0			0	0					0
12-Sep-19	% LEL		0	0	0	0	0	0			0	0					0
26-Sep-19	% LEL		0	0	0	0	0	0			0	0					0
9-Oct-19	% LEL		0	0	0	0	0	0			0	0					0
25-Oct-19	% LEL		0	0	0	0	0	0			0	0					0
4-Nov-19	% LEL		0	0	0	0	0	0			0	0					0
19-Nov-19	% LEL		0	0	0	0	0	0			0	0					0
4-Dec-19	% LEL		0	0	0	0	0	0			0	0					0
23-Dec-19	% LEL		0	0	0	0	0	0			0	0					0

Notes: - Combustible gas readings are in % LEL (% Lower Explosive Limit for Methane)
 - * Result is in % of Methane by volume in air (100% LEL for Methane = 5% Methane in air)
 - Blank denotes data not available
 - Moved into new office building in late June 2018; began monitoring.

- Gas monitoring well GW1 (south of lunchroom) decommissioned on September 10, 2007
 - Storage trailer removed from site in the summer of 2016 and lunchroom moved to the Green Barn shop in September 2016.
 - GW2 was decommissioned in mid-May 2017.
 - Former office (house) was demolished in August 2018; discontinued monitoring

